



www.oxmaint.com

CO Detector Inspection Checklist

No	Inspection Item	Status	Remarks
1	Verify CO detector is securely mounted at proper height	OK / PASS	
2	Ensure device location is unobstructed and accessible	OK / PASS	
3	Test sensor response using CO test spray	OK / PASS	
4	Check for false readings or sensor drift	OK / PASS	
5	Verify backup battery voltage is adequate	OK / PASS	
6	Check battery compartment for corrosion	OK / PASS	
7	Activate test button and confirm alarm sound	OK / PASS	
8	Ensure alarm resets after test	OK / PASS	
9	Check signal to central monitoring unit	OK / PASS	
10	Verify Wi-Fi/Zigbee/Bluetooth connection (if applicable)	OK / PASS	

Inspector Signature: _____

Barcode: |||||