



Compressor Heat Exchanger Inspection Checklist

No	Inspection Item	Status	Remark
1	Inspect external surface for damage or corrosion	OK	
2	Verify proper clearance around heat exchanger	OK	
3	Check insulation integrity (moisture, wear, gaps)	OK	
4	Test inlet and outlet temperature differential	OK	
5	Measure pressure drop across heat exchanger	OK	
6	Verify proper fluid flow rate	OK	
7	Inspect tube integrity (leaks, damage)	OK	
8	Check fin condition (bending, corrosion, fouling)	OK	
9	Perform chemical cleaning if fouling detected	OK	
10	Inspect seals and gaskets for damage	OK	

Technician Signature: _____

Barcode: []