



www.oxmaint.com

Cooling Tower Inspection & Cleaning Checklist

Sample Inspection Report

No	Inspection Item	Status	Remarks
1	Check exterior casing for cracks, leaks, or physical damage	OK / PASS	
2	Inspect support structure and anchoring for stability	OK / PASS	
3	Check access doors, panels, and gaskets for proper sealing	OK / PASS	
4	Examine fan deck integrity and overlays for damage	OK / PASS	
5	Verify safety railings, ladders, and platforms are secure	OK / PASS	

Signature (Technician): _____

Barcode: |||||