



www.oxmaint.com

Gas Leak Detection Inspection Checklist

No	Inspection Item	Status	Remarks
1	Ensure gas detectors are mounted per manufacturer's height	OK / PASS	
2	Verify detector placement avoids ventilation or dead zones	OK / PASS	
3	Check calibration using test gas per OEM schedule	OK / PASS	
4	Log calibration dates and sensor accuracy results	OK / PASS	
5	Test local audible and visual alarms	OK / PASS	
6	Check delay settings or suppression trigger points	OK / PASS	
7	Verify battery backup status or power supply continuity	OK / PASS	
8	Inspect wiring for frays or corrosion	OK / PASS	
9	Ensure detector transmits signal to control panel	OK / PASS	
10	Confirm SCADA/BMS logs the alarm data	OK / PASS	

Inspector Signature: _____

Barcode: |||||